

MATERIAL REACTION TO FIRE CLASSIFICATION REPORT

prepared in compliance with amended 5 of the French Home Office Regulation
dated November 21st, 2002 (Official Gazette dated December 31, 2002)

Valid five years from issue date

REPORT N° 14-02870 L

And appendices of 7 pages

MATERIAL presented by : CLIPSO PRODUCTIONS SAS
1 Rue de la Thur
Malmerspach
68550 SAINT AMARIN
FRANCE

TRADE NAME : 705 S / 507 P

BRIEF DESCRIPTION : Polyester knitted fabric coated with polyurethane fireproofed in the
mass
Nominal surface weight : 245 g/m²
Nominal thickness : 0.3 mm
Colours : optical white

TEST REPORT : N° 14-02870 dated September 18th, 2014

TESTS : Electrical burner test
Flame persistence test
Dripping test.

CLASSIFICATION : **M 1**

CLASSIFICATION DURATION (appendix 22): unlimited unless otherwise specified

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated June 3, 1994.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on September 18th, 2014

Director or empowered person

Bruno CHEVET



ACCREDITATION
N° 1-0101*
PORTÉE
COMMUNIQUÉE
SUR DEMANDE