

MATERIAL REACTION TO FIRE CLASSIFICATION REPORT

prepared in compliance with amended 5 of the French Home Office Regulation dated November 21st, 2002 (Official Gazette dated December 31, 2002)

Valid five years from issue date

CERTIFICATE N° 15-01475 L

And appendices of 11 pages

- MATERIAL presented by :** CLIPSO PRODUCTION SAS
1 rue de la Thur
Malmerspach
68550 SAINT AMARIN
FRANCE
- TRADE NAME :** 595 ATP
- BRIEF DESCRIPTION :** Knitted fabric made of polyester coated with flame retardant polyurethane
Nominal surface weight : 235 g/m²
Nominal thickness : 0.4 mm
Colours : translucent white
- TEST REPORT :** N° 15-01475_{EI-V1} on the 6th July, 2015
- TESTS :** Electrical burner test
Flame persistence test
Dripping test
Ageing in climatic room
- CLASSIFICATION :** **M 1**
- CLASSIFICATION DURATION (appendix 22):** Unlimited in indoor use (material not washable and not suitable for dry cleaning)


given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated June 3, 1994.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France on the 6th July, 2015
Director or empowered person

Bruno CHEVET

PO 



ACCREDITATION
N° 1-0101*
PORTÉE
COMMUNIQUÉE
SUR DEMANDE